

**ADDENDUM NO. 1
TO
CONTRACT DOCUMENTS AND SPECIFICATIONS
FOR
GROTON ROAD WATER MAIN
TOWN OF WESTFORD, MASSACHUSETTS**

This Addendum No. 1 forms a part of the Contract Documents and modifies the Bidding Documents dated October 2008 as noted below. Acknowledge receipt of this Addendum in the space provided in DOCUMENT 00300, BID FORM. Failure to do so may subject the Bidder to disqualification.

This Addendum consists of four (4) pages and one attachment (1 page).

CHANGES TO BE MADE TO CONTRACT DOCUMENTS

1. SECTION 00100, INSTRUCTIONS TO BIDDERS

A. Page 00100-2, Article 3.5., replace in its entirety with the following:

“3.5 List of required Bid Documents to be completed and submitted:

- 1. FORM FOR GENERAL BID Document 00300
- 2. Bid Security..... See Article 11, below
- 3. MDRP Statement of Intent to Comply.....See attachment”

2. SECTION 00300, BID FORM

A. Page 00300-2, Item (6), delete in its entirety and replace with the following:

“(6) Bidder hereby agrees to commence the Work required by the Contract Documents within ten (10) calendar days after a date to be specified in the Notice to Proceed and will complete the scope of work associated with the Base Bid (excluding final pavement and loaming/seeding) within 30 working days (60 calendar days), unless the period for Completion is extended otherwise by the Contract Documents. Bidder hereby agrees that the scope of work associated with Additive Alternate A and Additive Alternate B (excluding final pavement and loaming/seeding) will start on May 1, 2009 and shall be completed within the following specified time frames, dependent upon the extent of work to be awarded, unless the period for Completion is extended otherwise by the Contract Documents.

Additive Alternate A	30 working days, 60 calendar days
Additive Alternates A and B	80 working days, 130 calendar days”

B. Page 00300-2, Item (7), delete in its entirety and replace with the following:

“(7) Bidder hereby agrees to complete the scope of work associated with the Base Bid (inclusive of final pavement and loaming/seeding) within 240 days after the date to be specified in the Notice to Proceed, with onsite working days limited to an additional 10 working days beyond that noted in (6) above for final pavement and loaming/seeding. Bidder hereby agrees to complete the scope of work associated with Additive Alternate A and Additive Alternate B (inclusive of final pavement and loaming/seeding) within 365 days after the date to be specified in the Notice to Proceed, with onsite working days limited to the following additional time beyond that noted in (6) above for final pavement and loaming/seeding, dependent upon the extent of the work awarded:

Additive Alternate A	10 working days
Additive Alternates A and B	20 working days”

C. Page 00300-2, delete the following paragraph in its entirety:

“The unit prices listed for each Additive Alternate are to be the same as those provided under the Base Bid. The price of Bid Item 1 (Mobilization/Demobilization) may change with the scope of work although it may not be greater than 5% of the sum of the other bid items listed under the respective Base Bid or Additive Alternate A or Additive Alternate B.”

D. Page 00300-13, add the following note:

“The price bid for Item 1 shall not be greater than 5% of the sum of the other bid items listed under the Base Bid. The price bid for Item A-1 shall not be greater than 5% of the sum of the other bid items listed under Additive Alternate A. The price bid for Item B-1 shall not be greater than 5% of the sum of the other bid items listed under Additive Alternate B.”

E. Add the attached document as 00300-16, entitled the Massachusetts Diesel Retrofit Program (MDRP) Statement of Intent to Comply.

3. SECTION 00500, FORM FOR AGREEMENT

A. Page 00500-1, Item 3., delete in its entirety and replace with the following:

“3. The Contractor will commence the Work required by the Contract Documents within ten (10) calendar days after a date to be specified in the Notice to Proceed and will complete the scope of work associated with the Base Bid (excluding final pavement and loaming/seeding) within 30 working days (60 calendar days), unless the period for Completion is extended otherwise by the Contract Documents. The Contractor will commence the scope of work associated with Additive Alternate A and Additive Alternate B (excluding final pavement and loaming/seeding) on May 1, 2009 and will complete the work associated with Additive Alternate A and Additive Alternate B (excluding final pavement and loaming/seeding) within the following specified time frames, dependent upon the extent of work to be awarded, unless the period for Completion is extended otherwise by the Contract Documents.

Additive Alternate A	30 working days, 60 calendar days
Additive Alternates A and B	80 working days, 130 calendar days”

B. Page 00500-1, Item 4., delete in its entirety and replace with the following:

“4. The Contractor will complete the scope of work associated with the Base Bid (inclusive of final pavement and loaming/seeding) within 240 days after the date to be specified in the Notice to Proceed, with onsite working days limited to an additional 10 working days beyond that noted in Item 3 above for final pavement and loaming/seeding. The Contractor will complete the scope of work associated with Additive Alternate A and Additive Alternate B (inclusive of final pavement and loaming/seeding) within 365 days after the date to be specified in the Notice to Proceed, with onsite working days limited to the following additional time beyond that noted in Item 3 above for final pavement and loaming/seeding, dependent upon the extent of the work awarded:

Additive Alternate A	10 working days
Additive Alternates A and B	20 working days”

4. SECTION 00700, GENERAL CONDITIONS

A. Add the following note to this section, as it relates to the entire document.

“This document is EJCDC Document C-700 (2007 Edition) as issued by the National Society for Professional Engineers for EJCDC and is copyright protected. All proprietary rights in this document are and shall remain the property of EJCDC.”

5. SECTION 00858, SPECIAL CONDITIONS – PERMITS

A. Note the following exceptions to the Town of Westford Standards for Street and Sidewalk Excavations:

1. Permit fee shall be waived.
2. Insurance requirements and performance bond requirements are superseded by DOCUMENT 00700, GENERAL CONDITIONS and SECTION 00800, SUPPLEMENTARY CONDITIONS.
3. Limits on work between November 15th and April 15th will be waived.
4. Costs associated with any required inspection of the work will be paid directly by the Owner and shall not be included in the Contractor’s bid.
5. Costs associated with any required police details for traffic control and/or fire department details for blasting will be paid directly by the Owner and shall not be included in the Contractor’s bid.

6. SECTION 02500, DUCTILE IRON PIPE AND FITTINGS

A. Page 02500-3, Paragraph 2.03 C., add the following sentence:

“Tees for hydrant branches shall be mechanical joint valve anchoring tees, with an integral rotating gland on the branch.”

B. Page 02500-3, Paragraph 2.03 D., delete in its entirety.

- C. Page 02500-3, Paragraph 2.04, add the following sentence:
 “Glands and gaskets shall conform to the requirements of AWWA C111.”
 - D. Page 02500-4, Paragraph 2.06, delete in its entirety and replace with the following:
 “2.06 SOLID SLEEVES
 - A. Solid sleeves shall be used at all connections to existing water mains, as required to achieve a watertight connection.
 - B. Solid sleeves shall be long body type, ductile iron with mechanical joints. All solid sleeves shall conform to the weights and dimensions shown in the latest edition of the Ductile Iron Pipe Research Association (DIPRA) “Handbook of Ductile Iron Pipe” and be provided complete with all joint accessories. Hardware shall be galvanized steel.
 - C. Solid sleeves shall be epoxy coated (interior and exterior). Coating shall be NSF certified for potable water use.
 - D. Solid sleeves and joint accessories shall have a pressure rating at least equal to that of the pipe.
 - E. Gaskets shall be NSF certified for use with potable water.”
 - E. Page 02500-4, Paragraph 2.07, delete subparagraph B and replace with the following:
 “B. Restraint of push-on joints, as required to obtain the restrained lengths noted on the drawings, shall be Field-Lok gasket as manufactured by United States Pipe and Foundry Company or approved equal.”
7. SECTION 02510, HYDRANTS, VALVES AND APPURTENANCES
- A. Page 02510-2, Paragraph 1.05 D., delete in its entirety.
 - B. Page 02510-4, Paragraph 2.03 A., replace the first sentence with the following:
 “Resilient seated wedge type gate valves shall be manufactured to meet all applicable requirements of AWWA C509 or AWWA C515.”
 - C. Page 02510-4, Paragraph 2.03 C., at the end of the first sentence, eliminate the words “or attached to the face of the wedges with stainless steel screws”.
 - D. Page 02510-4, Paragraph 2.03, add the following as subparagraph F.
 “F. Valves shall be as manufactured by Mueller Company, American Darling, M&H, Kennedy Valve or approved equal.”
 - E. Page 02510-5, Paragraph 2.04, add the following as subparagraph F.
 “F. Each valve box including cover shall weigh at least 100 pounds.”

END OF TEXT